

D-R STANDARD TYPE TWO- AND THREE-UNIT (CIRCUIT "A")

REGULATORS




Figure 1—Delco-Remy standard type, two-unit voltage regulator with cover removed so the two units can be seen.

The Delco-Remy two- and three-unit standard regulators illustrated in Figures 1 and 2 are designed for use with generators which have the field circuit insulated in the generator but grounded in the regulator (circuit "A"). This is in contrast with the Delco-Remy heavy-duty regulators discussed in Bulletins 1R-123, 1R-133 and 1R-139 which are used with generators having their fields grounded internally rather than in the regulator (circuit "B"). The two types of regulator are not interchangeable. These regulators in the 1118300 and 1118700 series differ essentially from the 1118200 series discussed in Bulletin 1R-115 only in the method of adjustment and in the manner in which the resistances are connected into the field circuit.

TWO-UNIT REGULATOR

The regulator in Figure 1 consists of two units, a cutout relay and a voltage regulator, and is for use with Delco-Remy third-brush generators with externally grounded field circuits. The cutout relay closes the generator-to-battery circuit when the generator voltage is sufficient to charge the battery, and it opens the circuit when the generator slows




Figure 2—Delco-Remy standard type, three-unit current and voltage regulator with the cover removed so the three units can be seen.

or stops. The voltage regulator is a voltage limiting device that prevents the voltage from exceeding a specified maximum and reduces generator output to the value required for any particular condition of battery charge and electrical load. Figure 3 is a wiring diagram of this regulator.

CUTOUT RELAY

The cutout relays on the two-unit and three-unit regulators are of similar construction and have similar wiring circuits (Figs. 3 and 4). The relay has two windings assembled on one core, a series winding of a few turns of heavy wire (shown in solid red) and a shunt winding of many turns of fine wire (shown in dashed red). The shunt winding is shunted across the generator so that generator voltage is impressed upon it at all times. The series winding is connected in series with the charging circuit so that generator output passes through it.

The relay core and windings are assembled into a frame. A flat steel armature is attached to the frame by a flexible hinge so that it is centered just above the end of the core. The armature has one or two contact points which are located just above




Figure 3—Wiring circuit of Delco-Remy standard type, two-unit regulator shown in Figure 1. The shunt windings in the cut-out relay and voltage regulator units are shown in dashed red. The series winding in the cutout relay is shown in solid red. The series winding in the voltage regulator is shown in blue.

a similar number of stationary contact points. When the generator is not operating the armature contact points are held away from the stationary points by the tension of a flat spring riveted on the side of the armature.

CUTOUT RELAY ACTION—When the generator voltage builds up to a value great enough to charge the battery, the magnetism induced in the relay core is sufficient to overcome the armature spring tension and pull the armature toward the core so that the contact points close. This completes the circuit between the generator and battery. The current which flows from the generator to the battery passes through the series winding in the proper direction to add to the magnetism holding the armature down and the contact points closed.

When the generator slows down or stops, current begins to flow from the battery to the generator. This reverses the direction that the current flows through the series winding, thus causing a reversal of the series winding magnetic field. The magnetic field of the shunt winding does not reverse. Therefore, instead of helping each other, the two windings now magnetically oppose so that the resultant magnetic field becomes insufficient to hold the armature down. The flat spring pulls the armature away from the core so that the points separate; this opens the circuit between the generator and battery.

VOLTAGE REGULATOR

The voltage regulator units in the two-unit and three-unit regulators are of similar construction and have similar wiring circuits (Figs. 3 and 4). The regulator has two windings assembled on a single core, a shunt winding consisting of many turns of fine wire (shown in dashed red) which is shunted across the generator, and a series winding of a few turns of relatively heavy wire (shown in solid blue) which is connected in series with the generator field circuit when the regulator contact points are closed.

The windings and core are assembled into a frame. A flat steel armature is attached to the frame by a flexible hinge so that it is just above the end of the core. The armature contains a contact point which is just beneath a stationary contact point. When the voltage regulator is not operating, the tension of a spiral spring holds the armature away from the core so that the points are in contact and the generator field circuit is completed to ground through them.

VOLTAGE REGULATOR ACTION—When the generator voltage reaches the value for which the voltage regulator is adjusted, the magnetic field produced by the two windings (shunt and series) overcomes the armature spring tension and pulls the armature down so that the contact points separate. This inserts resistance into the generator




Figure 4—Wiring circuit of Delco-Remy standard type, three-unit regulator shown in Figure 2. The shunt windings in the cutout relay and voltage regulator are shown in dashed red. The series windings in the cutout relay and current regulator are shown in solid red. The series winding in the voltage regulator is shown in blue.

field circuit so that the generator field current and voltage are reduced. Reduction of the generator voltage reduces the magnetic field of the regulator shunt winding. Also, opening the regulator points opens the regulator series winding circuit so that its magnetic field collapses completely. The consequence is that the magnetic field is reduced sufficiently to allow the spiral spring to pull the armature away from the core so that the contact points again close. This directly grounds the generator field circuit so that generator voltage and output increase. The above cycle of action again takes place and the cycle continues at a rate of 50 to 200 times a second, regulating the voltage to a predetermined value. With the voltage thus limited the generator supplies varying amounts of current to meet the varying states of battery charge and electrical load.

THREE-UNIT REGULATOR

The three-unit regulator is designed for use with Delco-Remy shunt type generators with externally grounded field circuits. The regulator contains a cutout relay, a voltage regulator, and a current regulator. The operation of the first two has already been discussed, since they operate in the same manner as the cutout relay and voltage regulator in the two-unit regulator. Operation of the current regulator is discussed here.

CURRENT REGULATOR

The current regulator has a series winding of a few turns of heavy wire (shown in red) which carries all generator output. The winding core is assembled into a frame. A flat steel armature is attached to the frame by a flexible hinge so that it is just above the core. The armature has a contact point which is just below a stationary contact point. When the current regulator is not operating, the tension of a spiral spring holds the armature away from the core so that the points are in contact. In this position the generator field circuit is completed to ground through the current regulator contact points in series with the voltage regulator contact points.

CURRENT REGULATOR ACTION—When the load demands are heavy, as for example, when electrical devices are turned on and the battery is in a discharged condition, the voltage may not increase to a value sufficient to cause the voltage regulator to operate. Consequently, generator output will continue to increase until the generator reaches rated maximum. This is the current value for which the current regulator is set. Therefore, when the generator reaches rated output, this output, flowing through the current regulator winding, creates sufficient magnetism to pull the current regulator armature down and open the contact points. With the points open, resistance is inserted into the generator field circuit so that the generator output is reduced.



As soon as the generator output starts to fall off, the magnetic field of the current regulator winding is reduced, the spiral spring tension pulls the armature up, the contact points close and directly connect the generator field to ground. Output increases and the above cycle is repeated. The cycle continues to take place while the current regulator is in operation 50 to 200 times a second, preventing the generator from exceeding its rated maximum.

When the electrical load is reduced (electrical devices turned off or battery comes up to charge), then the voltage increases so that the voltage regulator begins to operate and tapers the generator output down. This prevents the current regulator from operating. Either the voltage regulator or the current regulator operates at any one time—the two do not operate at the same time.

RESISTANCES

The current and voltage regulator circuits use a common resistor (Fig. 4) which is inserted in the field circuit when either the current or voltage regulator operates. A second resistor (Fig. 4) is connected between the regulator field terminal and the cutout relay frame, which places it in parallel with the generator field coils. The sudden reduction in field current occurring when either the current or voltage regulator contact points open, is accompanied by a surge of induced voltage in the field coils as the strength of the magnetic field changes. These surges are partially dis-

sipated by the two resistors, thus preventing excessive arcing at the contact points.

NOTE: The resistances in this series of regulators are connected differently than those in the 1118200 series. See Delco-Remy Service Bulletin 1R-115 for description of 1118200 wiring circuit.

TEMPERATURE COMPENSATION

Voltage regulators are compensated for temperature by means of a bi-metal thermostatic hinge on the armature. This causes the regulator to regulate for a higher voltage when cold which partly compensates for the fact that a higher voltage is required to charge a cold battery. Many current regulators also have a bi-metal thermostatic hinge on the armature. This permits a somewhat higher generator output when the unit is cold but causes the output to drop off as temperature increases.

REGULATOR POLARITY

Some regulators are designed for use with negative grounded batteries while other regulators are designed for use with positive grounded batteries. Using the wrong polarity regulator on an installation will cause the regulator contact points to pit badly and give very short life. As a safeguard against installation of the wrong polarity regulator, all regulators in the 1118300 and 1118700 series have the model number and the polarity clearly stamped on the end of the regulator base.

REGULATOR MAINTENANCE

GENERAL INSTRUCTIONS

1. Mechanical checks and adjustments (air gaps, point opening) must be made with battery disconnected and regulator preferably off the vehicle.

CAUTION: The cutout relay contact points must never be closed by hand with the battery connected to the regulator. This would cause a high current to flow through the units which would seriously damage them.

2. Electrical checks and adjustments may be made either on or off the vehicle. The regulator must always be operated with the type generator for which it is designed.

3. The regulator must be mounted in the operating

position when electrical settings are checked and adjusted and it must be at operating temperature.

4. After any tests or adjustments the generator on the vehicle must be repolarized after leads are connected but before the engine is started, as follows:

REPOLARIZING GENERATOR

After reconnecting leads, momentarily connect a jumper lead between the "GEN" and "BAT" terminals of the regulator. This allows a momentary surge of current to flow through the generator which correctly polarizes it. Failure to do this may result in severe damage to the equipment since reversed polarity causes vibration, arcing and burning of the relay contact points.




S E R V I C E


B U L L E T I N

QUICK CHECKS OF GENERATOR AND REGULATOR

In analyzing complaints of generator-regulator operation, any of several basic conditions may be found.



(1) Fully Charged Battery and Low Charging Rate—This indicates normal generator-regulator operation. Regulator settings may be checked as outlined in the following section.




(2) Fully Charged Battery and a High Charging Rate—This indicates that the voltage regulator is not reducing the generator output as it should. A high charging rate to a fully charged battery will damage the battery and the accompanying high voltage is very injurious to all electrical units.


This operating condition may result from:

- Improper voltage regulator setting.
- Defective voltage regulator unit.
- Grounded generator field circuit (in either generator, regulator or wiring).
- Poor ground connection at regulator and high speed operation.
- High temperature which reduces the resistance of the battery to charge so that it will accept a high charging rate even though the voltage regulator setting is normal.

If the trouble is not due to high temperature, determine the cause of trouble by disconnecting the lead from the regulator "F" terminal with the generator operating at medium speed. If the output remains high, the generator field is grounded either in the generator (see Service Bulletin 1G-150) or in the wiring harness. If the output drops off the regulator is at fault and it should be checked for a high voltage setting or grounds and poor ground connections.



(3) Low Battery and High Charging Rate—This is normal generator-regulator action. Regulator settings may be checked as outlined in the following section.



(4) Low Battery and Low or No Charging Rate—

This condition could be due to:

- Loose connections, frayed or damaged wires.
- Defective battery.
- High circuit resistance.
- Low regulator setting.
- Oxidized regulator contact points.
- Defects within the generator.

If the condition is not caused by loose connections, frayed or damaged wires, proceed as follows to locate cause of trouble.

To determine whether the generator or regulator is at fault, momentarily ground the "F" terminal of the regulator and increase generator speed. If the output does not increase, the generator is probably at fault and it should be checked as outlined in Service Bulletin 1G-150. If the generator output increases, the trouble is due to:

- A low voltage (or current) regulator setting.
- Oxidized regulator contact points which insert excessive resistance into the generator field circuit so that output remains low.
- Generator field circuit open within the regulator at the connections or in the regulator winding.

(5) Burned Resistances, Windings or Contacts—These result from open circuit operation, open resistance units, or high resistance in the charging circuit. Where burned resistances, windings or contacts are found, always check car wiring before installing a new regulator. Otherwise, the new regulator may also fail in the same way.

(6) Burned Relay Contact Points—This may be due to reversed generator polarity. Generator polarity must be corrected as explained on page 4 after any checks of the regulator or generator, or after disconnecting and reconnecting leads.



CLEANING CONTACT POINTS

The contact points of a regulator will not operate indefinitely without some attention. It has been found that a great majority of all regulator trouble can be eliminated by a simple cleaning of the contact points, plus some possible readjustment. The flat points should be cleaned with a spoon or riffler file. On negative grounded regulators which have the flat contact point on the regulator armatures, loosen the contact bracket mounting screws so that the bracket can be tilted to one side (Fig. 5). On positive grounded regulators, the flat point is in the upper contact bracket so the bracket must be removed for cleaning the points. A flat file cannot be used successfully to clean the flat contact points since it will not touch the center of the flat point where point wear is most apt to occur. **NEVER USE EMERY CLOTH OR SANDPAPER TO CLEAN THE CONTACT POINTS.** Remove all the oxides from the contact points but note that it is not necessary to remove any cavity that may have developed.




Figure 5—Illustrating use of spoon or riffler file to clean flat contact points in regulator.

TWO-UNIT REGULATOR CHECKS AND ADJUSTMENTS

(See Delco-Remy Service Bulletins 1R-180 and 1R-185 for specifications)

CUTOUT RELAY CHECKS AND ADJUSTMENTS

The cutout relay requires three checks and adjustments: air gap, point opening and closing voltage. The air gap and point opening adjustments must be made with the battery disconnected.




Figure 6—Cutout relay air gap check and adjustment. Battery must be disconnected when this check is made.




Figure 7—Cutout relay point opening check and adjustment. Battery must be disconnected when this check is made.

AIR GAP—Place fingers on armature directly above core and move armature down until points just close and then measure air gap between armature and center of core (Fig. 6). On multiple contact point relays, make sure that all points



close simultaneously. If they do not, bend spring finger so they do. To adjust air gap, loosen two screws at the back of relay and raise or lower the armature as required. Tighten screws after adjustment.

POINT OPENING—Check point opening and adjust by bending the upper armature stop (Fig. 7).




Figure 8—Voltmeter connections to check cutout relay closing voltage. Connections are similar for both two-unit and three-unit standard type regulators.

CLOSING VOLTAGE—To check the closing voltage of the cutout relay, connect the regulator to the proper generator and battery, connect a voltmeter between the regulator "GEN" terminal and regulator base, as shown in Figure 8. Slowly increase the generator speed and note relay closing voltage. Decrease generator speed and make sure that cutout relay contact points open. An alternate method is to use a variable resistor connected in the field circuit as shown in Figure 8. (15 ohm-25 watt for 6-volt, 25 ohm-25 watt for 12- and 24-volt). With generator operating at medium speed and resistance all in, slowly decrease the resistance until the cutout relay points close and note the closing voltage. Adjust closing voltage by turning adjusting screw (Fig. 9). Turn screw clockwise to increase spring tension and closing voltage, and turn screw counterclockwise to decrease closing voltage.

VOLTAGE REGULATOR

Two checks and adjustments are required on the voltage regulator, air gap and voltage setting.




Figure 9—Adjustment of cutout relay closing voltage.

AIR GAP—To check air gap, push armature down until the contact points are just touching and then measure air gap (Fig. 10). Adjust by loosening the contact mounting screws and raising or lowering the contact bracket as required. Be sure the points are lined up, and tighten screws after adjustment.

VOLTAGE SETTING—There are two ways to check the voltage setting—the fixed resistance method and the variable resistance method (Figs. 11 and 12).




Figure 10—Voltage regulator air gap check and adjustment.




Figure 11—Fixed resistance and voltmeter connections to check voltage regulator setting by fixed resistance method. Fixed resistance leads shown in red and voltmeter leads shown in blue. Connections are similar for both two-unit and three-unit standard type regulator.

FIXED RESISTANCE METHOD—With the fixed resistance method, a fixed resistance is substituted for the external charging circuit by disconnecting the battery lead at the regulator and connecting the resistance between the regulator "BAT" terminal and ground. A test voltmeter is connected in parallel with the fixed resistance as shown in Figure 11. The resistance must be $\frac{3}{4}$ ohm* for 6-volt units, $1\frac{1}{2}$ ohms* for 12-volt units, 7 ohms for 24-volt units. It must be capable of carrying 10 amperes for 6- and 12-volt systems, 6-7 amperes for 24-volt systems, without any change of resistance with temperature changes.

*NOTE: With all 6-volt regulators having current ratings less than 15 amperes, it is necessary to use a $1\frac{1}{2}$ ohm fixed resistance to avoid interference from the current regulator. With all 12-volt regulators having current ratings less than 15 amperes, a $2\frac{1}{4}$ -ohm fixed resistance ($\frac{3}{4}$ ohm and $1\frac{1}{2}$ ohm resistors in series) must be used for the same reason.

With generator operating at specified speed and with regulator at operating temperature, note voltage setting. Cover must be in place.

To adjust voltage setting, turn adjusting screw (Fig. 13). Turn screw clockwise to increase voltage setting and counterclockwise to decrease voltage setting.

CAUTION: If adjusting screw is turned down (clockwise) beyond normal adjustment range, spring support may fail to return when pressure is relieved. In such case, turn screw counterclockwise until sufficient clearance develops between screw head and spring support, then bend spring support upward carefully with small pliers until contact is made with screw head. Final setting of the unit should always be approached by increas-




Figure 12—Voltmeter, ammeter and variable resistance connections for checking voltage regulator setting by the variable resistance method. Variable resistance and ammeter leads shown in red and voltmeter leads in blue. Connections are similar for both two-unit and three-unit standard type regulator.

ing spring tension, never by reducing it. If setting is too high, adjust unit below required value, and then raise to exact setting by increasing spring tension.

After each adjustment and before taking voltage reading, replace the regulator cover, reduce generator speed until relay points open and then bring the generator back to speed again.

VARIABLE RESISTANCE METHOD—Connect ammeter into charging circuit at "BAT" terminal of regulator with $\frac{1}{4}$ ohm variable resistance in series. Connect voltmeter from regulator "BAT" terminal to ground as shown in Figure 12. Increase generator to specified speed. If less than 8 amperes is obtained (or less than 4 amperes on low output 6- and 12-volt generators), turn on lights to permit increased generator output. Cut in resistance until output is reduced to 8-10 amperes (4-6 amperes on 6- and 12-volt generators having current ratings less than 15 amperes). Operate until regulator reaches operating temperature. Retard generator speed until relay points open and voltage is reduced to 2 volts for a 6-volt system, 4 volts for a 12-volt system, or 6 volts for a 24-

NOTE—It is very important that the variable resistance be connected at the "BAT" terminal as shown in Figure 12 rather than at the "GEN" terminal, even though these terminals are in the same circuit. An examination of the wiring diagram, Figure 3, will show that regulation begins at the point where the shunt windings are connected to the series circuit. Any small resistance added to the circuit between the generator and this point will simply be offset by a rise in generator voltage without affecting the output shown at the ammeter.




Figure 13—Adjusting voltage regulator setting.

volt system, then bring generator back to speed and note voltage setting. Voltage readings must be taken with regulator at operating temperature and with 8-10 amperes flowing (4-6 amperes on low output units). Cover must be in place.

Adjust regulator as previously explained. In using the variable resistance method, it is necessary to readjust the variable resistance after each voltage adjustment, and then reduce and increase generator speed before taking the voltage reading.

Specified Generator Speeds for Adjusting the Voltage Regulator




Figure 14—Quick method for cutting out voltage regulator in order to check current regulator setting.

1. For passenger cars and trucks, 3500 generator r.p.m.
2. Operating speed for constant speed engines (light aircraft engines included in this classification).
3. Governed speed for governed engines.

THREE-UNIT REGULATOR CHECKS AND ADJUSTMENTS

(See Delco-Remy Service Bulletin 1R-180 and 1R-185 for specifications)

The cutout relay and voltage regulator on the three-unit regulator are checked and adjusted in the same manner as the cutout relay and voltage regulator on the two-unit regulator.

CURRENT REGULATOR

Two checks and adjustments are required on the current regulator, air gap and current setting. The air gap on the current regulator is checked and adjusted in exactly the same manner as for the voltage regulator already described.

CURRENT SETTING—To check the current regulator setting, the voltage regulator must be prevented from operating. Four methods of preventing voltage regulator operation are available. Regardless of the method used, an ammeter must be connected into the charging circuit at the regulator "BAT" terminal. The first method should be used for preliminary checks whenever possible since it does not require removal of the regulator cover. The four methods are as follows:




Figure 15—Ammeter and jumper lead connections for checking current regulator setting by the jumper lead method. Ammeter leads and jumper lead shown in red.



1. QUICK CHECK METHOD—Insert screwdriver blade through oblong hole in base of regulator until contact is made with shield around resistor (Fig. 14). Be sure to keep screwdriver at right angles to base, and hold firmly in place during check so that blade touches regulator base and shield at same time. This temporarily cuts out voltage regulator unit. Turn on lights and accessories to prevent high voltage during the test. With ammeter connected as in Figure 15 and regulator at operating temperature, operate generator at specified speed, and note current setting. If necessary to adjust, remove cover and adjust in same manner as voltage regulator unit (Fig. 13) by turning adjusting screw clockwise to increase current setting or counterclockwise to decrease setting. See CAUTION note under Voltage Setting of Voltage Regulator. If unit is badly out of adjustment readjust as explained under REGULATOR SPRING REPLACEMENT.

2. JUMPER LEAD METHOD—Remove the regulator cover and connect a jumper lead across the voltage regulator contact points (Fig. 15). Turn on lights and accessories to prevent high voltage during the test. With generator operating at specified speed and with regulator at operating temperature, note the current setting.

3. BATTERY DISCHARGE METHOD—Partly discharge battery by cranking the engine for 30 seconds with ignition turned off. Never use cranking motor more than 30 seconds continuously since this would overheat and damage it. Immediately after cranking, start engine, turn on lights and accessories and note current setting with generator operating at specified speed.

4. LOAD METHOD—If a load approximating the current regulator setting is placed across the battery during the time that the current regulator setting is being checked, the voltage will not increase sufficiently to cause the voltage regulator to operate. This load may be provided by a carbon pile or a bank of lights.

IMPORTANT—When adjusting any current regulator the following must be observed:

1. All generators must be operated at a speed sufficient to produce current in excess of specified setting.

2. Voltage of the generator must be kept high enough to insure sufficient current output. (With 35 ampere generators it may be necessary to maintain the voltage above the voltage regulator setting. This can be done, where necessary, by decreasing the load across the battery or by raising the state of charge of the battery.)




Figure 16—Relationship of insulators, connector strap and upper contact support brackets in three-unit regulator.

REPAIR SECTION

REGULATOR SPRING REPLACEMENT

If it becomes necessary to replace the spiral spring on either the current or voltage regulator unit, the new spring should first be hooked on the lower spring support and then stretched up until it can be hooked at the upper end. Stretch the spring only by means of a screwdriver blade inserted between the turns (or in a similar manner)—do not pry the spring into place as this is likely to bend the spring supports. After installing a new spring, readjust the unit setting as already described.

REPLACING CONTACT SUPPORT BRACKETS

Voltage or current regulator contact support brackets can be replaced by following the relationship illustrated in Figure 16. Note particularly that the connector strap is insulated from the voltage regulator contact mounting screws while it is connected to the current regulator contact mounting screws. New bushings should always be used when installing a contact support bracket since the old bushing may be distorted or damaged.

RADIO BY-PASS CONDENSERS

The installation of radio by-pass condensers on the field terminal of the regulator or generator will cause the regulator contact points to burn and oxidize so that generator output will be reduced and a run-down battery will result. If a condenser is found to have been connected to either of these terminals, disconnect the condenser and clean the regulator contact points as previously explained.